

JENSEN HUGHES

Advancing the Science of Safety

Improving the Modeling of Electrical Cabinet Fires through RACHELLE-Fire


Session TH-32
RES Improving Realism in Fire Probabilistic Risk Assessments

Joelle DeJoseph, PE
March 10, 2016

Improving the Modeling of Electrical Cabinet Fires

Why is there a need for improvement?

Fire CDF Contribution by Ignition Source



© 2015 Jensen Hughes. All rights reserved.

www.jensenhughes.com

Improving the Modeling of Electrical Cabinet Fires

Removing known conservatisms through:

- Additional Experiments
 - NUREG/CR-7197; Heat Release Rates of Electrical Enclosure Fires (HELEN-Fire)
- Operating experience
 - Decades of fire event experience (EPRI's Update Fire Events Database – EPRI 1025284)
- Working group consisted of experienced fire protection and fire probabilistic risk assessment researchers and practitioners
 - Insights from practitioners to evolve methodology


www.jensenhughes.com

What's in RACHELLE-Fire?

Refining And Characterizing Heat Release Rates From Electrical Enclosures During Fire

Volume 1: Peak Heat Release Rates and Effect of Obstructed Plume

- Expanded classification of cabinets / enclosures
- Revised heat release rate distributions
- Fuel assessment impacting peak HRR
- Fire diameter sizing guidance
- Obstructed plume
- Pilot application



(NUREG-2178/EPRI 3002005578)

www.jensenhughes.com



RACHELLE-Fire Working Group

Results and approaches presented in RACHELLE-Fire represent the working groups consensus opinion

Representation was balanced between the regulator and the nuclear power industry

- Four members from the U.S. Nuclear Regulatory Commission (NRC) /National Laboratories
- Four members from Electric Power Research Institute (EPRI) /nuclear power industry

Comments from the regulator, the nuclear power industry, and the public were addressed by the working group.

www.jensenhughes.com



NUREG/CR-6850 / EPRI 1011989

HRR distributions from Table G-1

- Recommended HRR Values for Electrical Fires

Ignition Source	HRR kW (Btu/s)		Gamma Distribution	
	75th	98th	α	β
Vertical cabinets with qualified cable, fire limited to one cable bundle	69 ¹ (65)	211 ² (200)	0.84 (0.83)	59.3 (56.6)
Vertical cabinets with qualified cable, fire in more than one cable bundle	211 ³ (200)	702 ⁴ (665)	0.7 (0.7)	216 (204)
Vertical cabinets with unqualified cable, fire limited to one cable bundle	90 ¹ (85)	211 ² (200)	1.8 (1.8)	41.5 (39.5)
Vertical cabinets with unqualified cable, fire in more than one cable bundle closed doors	232 ¹ (220)	464 ³ (440)	2.6 (2.6)	67.8 (64.3)
Vertical cabinets with unqualified cable, fire in more than one cable bundle open doors	232 ¹ (220)	1002 ⁷ (950)	0.46 (0.45)	386 (366)

www.jensenhughes.com



HRR for Functionally Based Groups

Table 4-1
Peak HRR Distributions for Functionally Based Classification Groups 1, 2, and 3 Enclosures

Classification Group	Fuel Type* (TS/QTP/SIS or TP)	Alpha	Beta	75 th Percentile (kW)	98 th Percentile (kW)
1 – Switchgear and Load Centers	TS/QTP/SIS	0.32	79	30	170
	TP	0.99	44	60	170
2 – MCCs and Battery Chargers	TS/QTP/SIS	0.36	57	25	130
	TP	1.21	30	50	130
3 – Power Inverters	TS/QTP/SIS	0.23	111	25	200
	TP	0.52	73	50	200

www.jensenhughes.com



HRR for Volumetric Size Based Groups

Table 4-2
Peak Heat Release Rate Distributions for Classification Group 4 (All Other) Electrical Enclosures

Enclosure Class/Function Group	Enclosure Ventilation (Open or Closed Doors)	Fuel Type* (TS/QTP/SIS or TP Cables)	Gamma Distribution Characteristics											
			(a) Default				(b) Low Fuel Loading				(c) Very Low Fuel Loading			
			Alpha	Beta	75 th Percentile (kW)	98 th Percentile (kW)	Alpha	Beta	75 th Percentile (kW)	98 th Percentile (kW)	Alpha	Beta	75 th Percentile (kW)	98 th Percentile (kW)
4a – Large Enclosures >1.42 m ³ (>50 ft ³)	Closed	TS/QTP/SIS	0.23	223	50	400	0.23	111	25	200	0.38	32	15	75
		TP	0.52	145	100	400	0.52	73	50	200	0.88	21	25	75
	Open	TS/QTP/SIS	0.26	365	100	700	0.26	182	50	350	0.38	32	15	75
		TP	0.38	428	200	1000	0.38	214	100	500	0.88	21	25	75
4b – Medium Enclosures ≤1.42 m ³ (≤50 ft ³) and > 0.34 m ³ (12 ft ³)	Closed	TS/QTP/SIS	0.23	111	25	200	0.27	51	15	100	0.88	12	15	45
		TP	0.52	73	50	200	0.52	36	25	100	0.88	12	15	45
	Open	TS/QTP/SIS	0.23	182	40	325	0.19	92	15	150	0.88	12	15	45
		TP	0.51	119	80	325	0.30	72	25	150	0.88	12	15	45
4c – Small Enclosures ≤0.34 m ³ (12 ft ³)	Not Applicable	All	0.88	12	15	45	The fuel load characterization approach is not applicable to small enclosures.							

www.jensenhughes.com



Improvement on Distributions

Comparison of HRR distributions

- TS/QTP/SIS: Thermoset / *Qualified* Thermoplastic (passed IEEE-383 vertical flame spread test) / SIS
 - NUREG/CR-6850 → 2 HRR distributions
 - RACHELLE-Fire → 16 HRR distributions
- TP: *Unqualified* Thermoplastic
 - NUREG/CR-6850 → 3 HRR distributions
 - RACHELLE-Fire → 16 HRR distributions


www.jensenhughes.com



9

Obstructed Plume Simulations

RACHELLE-Fire presents methodology to correct for the ZOI due to the obstructed plume effect encountered in electrical enclosures.




www.jensenhughes.com



Unobstructed Plume

Smokeview 6.1.12 - Oct. 1 2014



Frame: 1
Time: 9.05

■ >200 (kW/m2)



mesh: 1

www.jensenhughes.com



Obstructed Plume

Smokeview 6.1.12 - Oct. 1 2014



Frame: 0
Time: 9.0

■ >200 (kW/m2)

mesh: 1


www.jensenhughes.com



Obstructed Plume Treatment in FPRA

Implementing the obstructed plume reduces the vertical ZOI

- Vertical → 24% reduction in vertical ZOI distance




www.jensenhughes.com

Obstructed Plume Treatment in FPRA

Did not explore improvements to horizontal ZOI

- Horizontal → none
- The thermal radiation ZOI extends farther than the plume will be shifted by the top obstruction



www.jensenhughes.com

Implementing RACHELLE-Fire

This activity requires verification of cabinet configurations!

What to look out for:

- Can't just apply the new HRR distributions to existing scenarios without checking
 - Function of electrical cabinet
 - Physical size of electrical cabinet
 - Open vs closed configuration
 - May need to open and explore internals of electrical cabinet

www.jensenhughes.com

What did we gain?

RACHELLE-Fire was able to reduce the conservatism found in electrical cabinet fire scenarios

- Guidance is user friendly
- Guidance is more applicable to the variety of cabinets
- Guidance is repeatable
- Guidance is more representative of industry fire OE (more small fires)

www.jensenhughes.com



QUESTIONS?

Contact

Joelle DeJoseph
+1 919-215-8735
jdejoseph@jensenhughes.com

For More Information Visit
www.jensenhughes.com


JENSEN HUGHES
Advancing the Science of Safety

www.jensenhughes.com

17